



Operating Level Scenarios for Key Storages in South East Queensland

Project Meeting

1 February 2011

11 – 12 noon

Draft Agenda

- 1. Introduction**
- 2. Strategic Issues – feedback from other agencies, releases etc**
- 3. Modelling Results to-date**
- 4. Additional Modelling – time to reach 40% and 60%**
- 5. Preparation of Report - progress**
- 6. Other business**

**Example Framework for Consideration of the Impact on SEQ Water Strategy
of Various Operating Levels for Wivenhoe Dam**

| Description | Base Case | Short Term Options | | | Intermediate (Ingenuity Option) | Long Term Option |
|----------------------------|-----------|--------------------|--|---|---------------------------------|---|
| | | 10% drawdown | 30% drawdown | 50% drawdown | | |
| Security | | | | | | |
| • Sufficiency | ok | ok | impacted | impacted | | Impacted – demand management/ manufactured water required |
| • Demand/Supply Balance | ok | ok | ok | ok | | Impacted – new infrastructure brought forward |
| Levers | | | | | | |
| • Level of Service changed | | | | | Review | |
| • Policy | | | | | Review | |
| • Assumptions | | | | | Review | |
| • Other | | | | | | |
| Input | | | | | | |
| • Allocation | ok | ok | Impacted? | Impacted? | | Impacted - Review required |
| • Yield | ok | ok | ok | ok | | Impacted |
| • Demand | ok | ok | ok | ok | | Potentially reduced |
| • Other | | | | | | |
| Price | | | | | | |
| | ok | ok | Grid operating costs / manufactured water triggered? | Grid operating costs / manufactured water triggered | | Yes – new price path? |

Note: above table is only an example – details are being assessed.

- SOA and Sulfuric acid

- NO_x conversion to NO₂

- Melting point of SO₃ & SO₂ conversion to SO₃ - NO_x conversion

- Ozone formation

- SO₂ removal from flue gas

Scenarios for Operation of Wivenhoe Dam January 2011

Preliminary Modelling results

Variation in Initial Wivenhoe Dam Level

An assessment of the risk criteria for three initial levels of Wivenhoe Dam was undertaken with the following assumptions:

- Initial levels of Wivenhoe Dam were 87.1%, 70% and 50%
- All other storages were set at 100% initially.
- No NPI2 for the duration of the modelling
- Simulation start was February 2011, with initial dam levels January 2011
- Price path 2010 – 2015 demands
- No Tugun desalination above 60% Key Water Grid Storages, full desalination below 60%

All scenarios passed the SOP risk criteria as shown below in the Table 1.

Table 1

| SOP | | | |
|--|--|----------------|----------------|
| Volume of water stored by all Key Water Grid Storages | Probability of reaching stored volume | | |
| | 1 year | 3 years | 5 years |
| 40% | <.2% | NA | <5% |
| 30% | NA | <.5% | <1% |

Scenario - Wivenhoe 87% (Case 2)

| Volume of water stored by all Key Water Grid Storages | Probability of reaching stored volume | | |
|--|--|----------------|----------------|
| | 1 year | 3 years | 5 years |
| 40% | >.01% | NA | 0.09% |
| 30% | NA | <.01% | <.01% |

Scenario - Wivenhoe 70% (Case 4)

| Volume of water stored by all Key Water Grid Storages | Probability of reaching stored volume | | |
|--|--|----------------|----------------|
| | 1 year | 3 years | 5 years |
| 40% | <.01% | NA | 0.20% |
| 30% | NA | <.01% | 0.01% |

Scenario - Wivenhoe 50% (Case 6)

| Volume of water stored by all Key Water Grid Storages | Probability of reaching stored volume | | |
|--|--|----------------|----------------|
| | 1 year | 3 years | 5 years |
| 40% | <.01% | NA | 0.48% |
| 30% | NA | <.01% | 0.01% |

Below in Table 2 are some of the results comparing the probability of reaching 40% for the scenarios run so far:

Table 2

| Case | % Reduction Wivenhoe (from full supply) | Volume of Water Released from Wivenhoe Dam (ML) | % reduction of Grid 12 Storages (from full supply) | Probability of reaching 60% within 5 years (desalination trigger) | Probability of reaching 40% within 5 years (PRW trigger) |
|------|---|---|--|---|--|
| 1 | 10 | 116,500 | 5.6 | | |
| 2 | 12.9 | 150,285 | 7.3 | | .09% |
| 3 | 20 | 233,000 | 11.3 | | |
| 4 | 30 | 349,500 | 16.9 | | .2% |
| 5 | 40 | 466,000 | 22.5 | | |
| 6 | 50 | 582,500 | 28.1 | | .48% |

Wivenhoe Dam initially at 50%, with varied initial Baroona Pocket and Hinze dam levels

An assessment of the effect on risk criteria of lower initial Hinze and Baroona Pocket dam levels was undertaken with the following assumptions:

- Initial level of Wivenhoe Dam 50%
- Baroona Pocket and Hinze Dam initial levels at 50%
- All other storages were set at 100% initially.
- No NPI2 for the duration of the modelling
- Simulation start was February 2011, with initial dam levels January 2011
- Price path 2010 – 2015 demands
- No Tugun desalination above 60% Key Water Grid Storages, full desalination below 60%

Both scenarios passed the risk criteria as shown in Table 3 below.

Table 3

| SOP | | | |
|---|---------------------------------------|---------|---------|
| Volume of water stored by all Key Water Grid Storages | Probability of reaching stored volume | | |
| | 1 year | 3 years | 5 years |
| 40% | <.2% | NA | <5% |
| 30% | NA | <.5% | <1% |

| 50/50/50% | | | |
|---|---------------------------------------|---------|---------|
| Volume of water stored by all Key Water Grid Storages | Probability of reaching stored volume | | |
| | 1 year | 3 years | 5 years |
| 40% | <.01% | NA | 0.49% |
| 30% | NA | 0.01% | .03% |

Table 4 compares the risk criteria for all scenarios.

Table 4

| Wivenhoe/Baroon/Hinze levels | 50/50/50 | 50/100/100 | 70/100/100 | 87/100/100 | SOP |
|------------------------------|----------|------------|------------|------------|------|
| 40% SEQ volume | | | | | |
| 1 year | <.01% | <.01% | <.01% | <.01% | <.2% |
| 5 years | 0.49% | 0.48% | 0.20% | 0.09% | <5% |
| 30% SEQ volume | | | | | |
| 3 years | 0.01% | <.01% | <.01% | <.01% | <.5% |
| 5 years | 0.03% | <.01% | 0.01% | <.01% | <1% |

Storage behaviour curves for varying probabilities of exceedance are shown below in Figures 1 and 2.

DRAFT



Figure 1**Figure 2**

Figure 1: Water Balance




Figure 2: Storage Levels - "Grid 12"




Figure 3: Drought Response Storage Trigger Points

Table A: Impact of Reduced Consumption on the Timing of the Next Augmentation





Figure 4: Storage Levels with Drought Response Triggers



The next bulk water source will be required for a growth or drought trigger. Fig 1 shows likely timeframes for growth scenarios. Fig 2 shows that there is 1 in a 1000 probability that a drought trigger might occur in late 2014 requiring construction to commence in 2017. Fig 3 illustrates the relationship of drought triggers to storage levels while Fig 4 illustrates that the present grid is sufficiently robust that on present population and planning based demand levels of 230 l/p/d construction of drought response infrastructure would not have been required for the Millennium drought.