

Table showing discrepancy between projected and actual releases on 11 January 2011
Prepared by Commission Staff

11 Jan 2011	Projected worst case release advised in email from Flood Operation Centre to BOM (and others) of 1.32 pm (cumecs)	Actual releases advised in email from Flood Operation Centre to BOM (and others) of 4.52 pm (cumecs)	Difference in release rate between projected and actual releases (cumecs)	Difference between projected and actual release volumes assuming constant releases for one hour (ML) (Flow in cumecs x 60 mins x 60 sec)
2.00pm	4228	4540	312	1,123,200
3.00pm	4519	5132	613	2,206,800
4.00pm	4527	5743	1216	4,377,600
Cumulative difference between projected and actual release volumes assuming constant releases at actual release rate advised in email of 4.52 pm for the period 2.00 pm to 5.00pm				7,707,600

QFCI

Date: 27/05/11

Exhibit Number: 498

JM